



**DISTRICT WATER TESTING LABORATORY**  
**PUBLIC HEALTH ENGINEERING DEPARTMENT**  
**GARHI BOLNI ROAD, REWARI, HARYANA**



**TEST REPORT**

Test Report No.: - REW/01860/5/2025	Report Issue Date: - 23/05/2025
Customer Name: - BLISS-Bountra Liberal International Smart School	Sample Location: - Opp.Rao Tularam Stadiym Delhi Road, Rewari
Customer's Address: - Opp.Rao Tularam Stadiym Delhi Road, Rewari	Sample Collected by: - Ms. Renu Sen
Your Reference No.: - Rewari PHESD No. 1 (U)	Sample Collected on: - 19/05/2025 12:34
Sample Type: - Chemical Test	Sample Received on: - 19/05/2025 15:40
Lab Job Order No.: - 01860	Sample Quantity: - 1 Liter

**Test Result**

Test started on: - 22/05/2025				Test completed on: - 22/05/2025		
Sr. No.	Tested Parameter	Results	Unit	Method	As per IS 10500:2012 RA 2018	
					Acceptable Limit	Permissible Limit
1	Turbidity	<0.5	NTU	APHA 2130 B, 2024	1 NTU	5 NTU
2	Taste	Agreeable	---	IS 3025 (Part-8) 2024	Agreeable	Agreeable
3	Odour	Agreeable	---	IS 3025 (Part-5) 2024	Agreeable	Agreeable
4	Colour	1	Hazen Unit	APHA 2120 B, C, 2024	5 Hazen Unit	15 Hazen Unit
5	Total Dissolve Solids @ 180 ° C	137	mg/l	APHA 2540 C, 2024	500 mg/l	2000 mg/l
6	Total Hardness (as CaCO <sub>3</sub> )	60	mg/l	APHA 2340 C, 2024	200 mg/l	600 mg/l
7	Calcium as (Ca)	<10	mg/l	APHA 3500-Ca B, 2024	75 mg/l	200 mg/l
8	Magnesium (Mg)	<10	mg/l	APHA 3500-Mg B, 2024	30 mg/l	100 mg/l
9	Total Alkalinity (as CaCO <sub>3</sub> )	75	mg/l	APHA 2320 B, 2024	200 mg/l	600 mg/l
10	Chlorides (as Cl)	40	mg/l	APHA 4500-Cl B, 2024	250 mg/l	1000 mg/l
11	Sulphate as (SO <sub>4</sub> )	12	mg/l	APHA 4500-SO <sub>4</sub> D & E, 2024	200 mg/l	400 mg/l
12	Fluoride as (F)	0.13	mg/l	APHA 4500-F D, 2024	1.0 mg/l	1.5 mg/l
13	Iron as (Fe)	<0.1	mg/l	APHA 3500-Fe B, 2024	1.0 mg/l	No Relaxation
14	Nitrate as (NO <sub>3</sub> )	6.2	mg/l	APHA 4500-NO <sub>3</sub> B, 2024	45 mg/l	No Relaxation
15	pH @ 25 ° C	8.24	----	APHA 4500-H+ B, 2024	6.5-8.5	No Relaxation
16	Conductivity (at 25°C)	----	μS/cm	APHA 2510 B (Laboratory Method): 2017, 2024	----	----

Specific contractual notes: -

- ◆ The results given above are related to the sample as received and tested in PHED Lab Rewari.
- ◆ The test report can't be regenerated/ re-produced in whole or part thereof without written permission of PHED Lab Rewari.
- ◆ The test report can't be used for any publicity or any legal purpose.
- ◆ The samples received shall be destroyed after 7 Days from the date of issue of the certificate.
- ◆ Reliability of water sample lies with sender/collector of water sample.

Review & Authorised By

Authorised Signatory

Chemist  
District Water Testing Lab  
PHED, Rewari, Haryana

X-----End-----X

1/1



Scanned with OKEN Scanner

Office of the Civil Surgeon, Rewari  
Sanitation & Hygienic Certificate

No.2025/ 1235

Dt. 11-4-25

Certified that the building of school Bountra Liberal Internation Smart School Rewari Haryana was inspected by the undersigned and found that the building of the school is in good sanitary, good drinking water and hygienic condition.

Deputy Civil Surgeon,  
For- Civil Surgeon, Rewari  
(Signature)